

Information requirements for heat pump space heaters and heat pump combination heaters				Source: 811/2013 & 813/2013
Model(s):	Outdoor unit: RAS-6WHNPE	Indoor unit: RWM-6.0N1E	Tank model: -	
Air-to-water heat pump:				Yes
Low-temperature heat pump:				No
Equipped with a supplementary heater:				Yes
Heat pump combination heater:				No

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
------	--------	-------	------	------	--------	-------	------

#### Average

Rated heat output (3)	Prated	14	kW	Seasonal space heating energy efficiency	$\eta_s$	134%	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	11,2	kW	Tj = - 7 °C	COPd	1,94	—
Tj = + 2 °C	Pdh	6,8	kW	Tj = + 2 °C	COPd	3,35	—
Tj = + 7 °C	Pdh	4,4	kW	Tj = + 7 °C	COPd	4,80	—
Tj = + 12 °C	Pdh	3,6	kW	Tj = + 12 °C	COPd	7,05	—
Tj = bivalent temperature	Pdh	11,2	kW	Tj = bivalent temperature	COPd	1,94	—
Tj = operation limit temperature	Pdh	10,5	kW	Tj = operation limit temperature	COPd	1,40	—
For air-to-water heat pumps: Tj = - 15 °C (if TOL < - 20 °C)	Pdh	X	kW	For air-to-water heat pumps: Tj = - 15 °C (if TOL < - 20 °C)	COPd	X	—
Bivalent temperature	Tbiv	-7	°C	For air-to-water HP : Operation limit temperature	TOL	-10	°C
Cycling interval capacity for heating	Pcyc	X	kW	Cycling interval efficiency	COPcyc	X	—
				Heating water operating limit temperature	WTOL	55	°C
Degradation coefficient (4)	Cdh	0,9	—	Supplementary heater			
Annual Energy consumption	Q <sub>HE</sub>	7662	kWh	Rated heat output (3)	Psup	3,5	kW
				Type of energy input	Electricity		

#### Colder

Rated heat output (3)	Prated	14	kW	Seasonal space heating energy efficiency	$\eta_s$	112%	%
				Supplementary heater			
Annual Energy consumption	Q <sub>HE</sub>	11633	kWh	Rated heat output (3)	Psup	4,1	kW
				Type of energy input	Electricity		

#### Warmer

Rated heat output (3)	Prated	14	kW	Seasonal space heating energy efficiency	$\eta_s$	176%	%
				Supplementary heater			
Annual Energy consumption	Q <sub>HE</sub>	4175	kWh	Rated heat output (3)	Psup	0	kW
				Type of energy input	Electricity		

#### Power consumption in modes other than active mode

Off mode	P <sub>OFF</sub>	0,019	kW
Thermostat-off mode	P <sub>TO</sub>	0	kW
Standby mode	P <sub>SB</sub>	0,019	kW
Crankcase heater mode	P <sub>CK</sub>	0	kW

#### Other items

Capacity control	fixed/variable	Variable	
Sound power level, indoors	L <sub>WA</sub>	39	dB(A)
Sound power level, outdoors	L <sub>WA</sub>	60	dB(A)

#### Outdoor heat exchanger

For air-to-water HP: Rated air flow rate	Q <sub>airsource</sub>	6000	m <sup>3</sup> /h
For air-to-water HP: Rated air flow rate	or Q <sub>watersource</sub>	X	m <sup>3</sup> /h
For water-to-water: Rated water flow rate	or Q <sub>brinesource</sub>	X	m <sup>3</sup> /h

#### For heat pump combination heater

Declared load profile	-	-	—	Water heating energy efficiency	$\eta_{wh}$	-	%
Daily electricity consumption	Q <sub>elec</sub>	-	kWh	Daily fuel consumption	Q <sub>fuel</sub>	X	kWh
Annual energy consumption	AEC	-	kWh				

Contact details	Johnson Controls Hitachi Air Conditioning Spain, S.A.U. Ronda Shimizu, 1. Políg. Ind. Can Torrella. 08233 Vacarisses (Barcelona)
<b>Legend</b>  For instructions on assembly, installation or maintenance, please refer to the operating manual. This document declares also information concerning disassembly, recycling and disposal.  (3) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).  (4) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.	